

## Equipment Datasheet — 200-P-208

Product Pump | HCU Unit

|                            |                         |
|----------------------------|-------------------------|
| Document ID                | DS-200-P-208            |
| Equipment Tag              | 200-P-208               |
| Equipment Name             | Product Pump            |
| Process Unit               | Hydrocracker Unit (200) |
| Manufacturer               | L&T Valves              |
| Install Date               | 2001-07-06              |
| Design Pressure            | 83.6 barg               |
| Design Temperature         | 459.7 degC              |
| Material of Construction   | Duplex Stainless Steel  |
| Criticality Rating         | Low                     |
| Governing SOP              | SOP-200-005             |
| Governing Safety Procedure | SP-003                  |

### 1. Equipment Description

200-P-208 is a Product Pump installed in the Hydrocracker Unit (HCU) at PRPC. It was supplied by L&T; Valves and commissioned on 2001-07-06. The equipment is classified as Low criticality within the unit's reliability programme.

### 2. Design Basis

Design pressure is rated at 83.6 barg with a design temperature of 459.7 degC. Primary material of construction is Duplex Stainless Steel, selected for compatibility with process fluid composition and corrosion allowance requirements specific to HCU service.

### 3. Operating & Safety References

Operation of 200-P-208 is governed by procedure SOP-200-005 (Recycle Gas Compressor Operating Envelope). Isolation and personnel safety during maintenance follow SP-003 (Confined Space Entry - Vessels and Tanks).

### 4. Maintenance Philosophy

200-P-208 is included in the HCU rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (Low).