

## Equipment Datasheet — 200-V-210

Low Pressure Separator | HCU Unit

|                            |                         |
|----------------------------|-------------------------|
| Document ID                | DS-200-V-210            |
| Equipment Tag              | 200-V-210               |
| Equipment Name             | Low Pressure Separator  |
| Process Unit               | Hydrocracker Unit (200) |
| Manufacturer               | Forbes Marshall         |
| Install Date               | 2017-03-12              |
| Design Pressure            | 138.1 barg              |
| Design Temperature         | 277.3 degC              |
| Material of Construction   | Cast Iron               |
| Criticality Rating         | Medium                  |
| Governing SOP              | SOP-200-004             |
| Governing Safety Procedure | SP-005                  |

### 1. Equipment Description

200-V-210 is a Low Pressure Separator installed in the Hydrocracker Unit (HCU) at PRPC. It was supplied by Forbes Marshall and commissioned on 2017-03-12. The equipment is classified as Medium criticality within the unit's reliability programme.

### 2. Design Basis

Design pressure is rated at 138.1 barg with a design temperature of 277.3 degC. Primary material of construction is Cast Iron, selected for compatibility with process fluid composition and corrosion allowance requirements specific to HCU service.

### 3. Operating & Safety References

Operation of 200-V-210 is governed by procedure SOP-200-004 (Hydrocracker Reactor Loading and Catalyst Activation). Isolation and personnel safety during maintenance follow SP-005 (Working at Height on Structures and Columns).

### 4. Maintenance Philosophy

200-V-210 is included in the HCU rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (Medium).