

Equipment Datasheet — 300-P-305

Boiler Feed Water Pump | UTIL Unit

Document ID	DS-300-P-305
Equipment Tag	300-P-305
Equipment Name	Boiler Feed Water Pump
Process Unit	Utilities & Offsites (300)
Manufacturer	Fluor Daniel India
Install Date	2019-06-15
Design Pressure	162.3 barg
Design Temperature	238.7 degC
Material of Construction	Carbon Steel
Criticality Rating	High
Governing SOP	SOP-300-009
Governing Safety Procedure	SP-007

1. Equipment Description

300-P-305 is a Boiler Feed Water Pump installed in the Utilities & Offsites (UTIL) at PRPC. It was supplied by Fluor Daniel India and commissioned on 2019-06-15. The equipment is classified as High criticality within the unit's reliability programme.

2. Design Basis

Design pressure is rated at 162.3 barg with a design temperature of 238.7 degC. Primary material of construction is Carbon Steel, selected for compatibility with process fluid composition and corrosion allowance requirements specific to UTIL service.

3. Operating & Safety References

Operation of 300-P-305 is governed by procedure SOP-300-009 (Cooling Tower Water Chemistry Control). Isolation and personnel safety during maintenance follow SP-007 (Emergency Shutdown (ESD) Activation Protocol).

4. Maintenance Philosophy

300-P-305 is included in the UTIL rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (High).