

Equipment Datasheet — 300-V-307

Deaerator | UTIL Unit

Document ID	DS-300-V-307
Equipment Tag	300-V-307
Equipment Name	Deaerator
Process Unit	Utilities & Offsites (300)
Manufacturer	BHEL
Install Date	2005-01-28
Design Pressure	61.8 barg
Design Temperature	266.2 degC
Material of Construction	Low Alloy Steel (Cr-Mo)
Criticality Rating	High
Governing SOP	SOP-300-009
Governing Safety Procedure	SP-008

1. Equipment Description

300-V-307 is a Deaerator installed in the Utilities & Offsites (UTIL) at PRPC. It was supplied by BHEL and commissioned on 2005-01-28. The equipment is classified as High criticality within the unit's reliability programme.

2. Design Basis

Design pressure is rated at 61.8 barg with a design temperature of 266.2 degC. Primary material of construction is Low Alloy Steel (Cr-Mo), selected for compatibility with process fluid composition and corrosion allowance requirements specific to UTIL service.

3. Operating & Safety References

Operation of 300-V-307 is governed by procedure SOP-300-009 (Cooling Tower Water Chemistry Control). Isolation and personnel safety during maintenance follow SP-008 (Chemical Handling and Spill Response - ETP).

4. Maintenance Philosophy

300-V-307 is included in the UTIL rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (High).