

Equipment Datasheet — 400-P-405

Tank Transfer Pump | TF Unit

Document ID	DS-400-P-405
Equipment Tag	400-P-405
Equipment Name	Tank Transfer Pump
Process Unit	Tank Farm / Storage (400)
Manufacturer	Godrej & Boyce
Install Date	2019-08-05
Design Pressure	37.0 barg
Design Temperature	135.8 degC
Material of Construction	Cast Iron
Criticality Rating	High
Governing SOP	SOP-400-012
Governing Safety Procedure	SP-005

1. Equipment Description

400-P-405 is a Tank Transfer Pump installed in the Tank Farm / Storage (TF) at PRPC. It was supplied by Godrej & Boyce and commissioned on 2019-08-05. The equipment is classified as High criticality within the unit's reliability programme.

2. Design Basis

Design pressure is rated at 37.0 barg with a design temperature of 135.8 degC. Primary material of construction is Cast Iron, selected for compatibility with process fluid composition and corrosion allowance requirements specific to TF service.

3. Operating & Safety References

Operation of 400-P-405 is governed by procedure SOP-400-012 (LPG Bullet Pressure Monitoring). Isolation and personnel safety during maintenance follow SP-005 (Working at Height on Structures and Columns).

4. Maintenance Philosophy

400-P-405 is included in the TF rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (High).