

Equipment Datasheet — 400-P-406

Product Loading Pump | TF Unit

Document ID	DS-400-P-406
Equipment Tag	400-P-406
Equipment Name	Product Loading Pump
Process Unit	Tank Farm / Storage (400)
Manufacturer	Godrej & Boyce
Install Date	1999-06-02
Design Pressure	12.4 barg
Design Temperature	249.8 degC
Material of Construction	Cast Iron
Criticality Rating	Low
Governing SOP	SOP-400-012
Governing Safety Procedure	SP-001

1. Equipment Description

400-P-406 is a Product Loading Pump installed in the Tank Farm / Storage (TF) at PRPC. It was supplied by Godrej & Boyce and commissioned on 1999-06-02. The equipment is classified as Low criticality within the unit's reliability programme.

2. Design Basis

Design pressure is rated at 12.4 barg with a design temperature of 249.8 degC. Primary material of construction is Cast Iron, selected for compatibility with process fluid composition and corrosion allowance requirements specific to TF service.

3. Operating & Safety References

Operation of 400-P-406 is governed by procedure SOP-400-012 (LPG Bullet Pressure Monitoring). Isolation and personnel safety during maintenance follow SP-001 (Lockout-Tagout (LOTO) for Rotating Equipment).

4. Maintenance Philosophy

400-P-406 is included in the TF rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (Low).