

Equipment Datasheet — 500-V-510

Sludge Thickener | ETP Unit

Document ID	DS-500-V-510
Equipment Tag	500-V-510
Equipment Name	Sludge Thickener
Process Unit	Effluent Treatment Plant (500)
Manufacturer	Emerson Process Management
Install Date	2011-12-05
Design Pressure	166.9 barg
Design Temperature	144.2 degC
Material of Construction	Stainless Steel 316L
Criticality Rating	High
Governing SOP	SOP-500-014
Governing Safety Procedure	SP-002

1. Equipment Description

500-V-510 is a Sludge Thickener installed in the Effluent Treatment Plant (ETP) at PRPC. It was supplied by Emerson Process Management and commissioned on 2011-12-05. The equipment is classified as High criticality within the unit's reliability programme.

2. Design Basis

Design pressure is rated at 166.9 barg with a design temperature of 144.2 degC. Primary material of construction is Stainless Steel 316L, selected for compatibility with process fluid composition and corrosion allowance requirements specific to ETP service.

3. Operating & Safety References

Operation of 500-V-510 is governed by procedure SOP-500-014 (Oil-Water Separator Skimming Procedure). Isolation and personnel safety during maintenance follow SP-002 (Hot Work Permit and Fire Watch).

4. Maintenance Philosophy

500-V-510 is included in the ETP rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (High).