

Inspection Report — 500-V-510

Ultrasonic Thickness | 2024-10-14

Report ID	IR-500-V-510-2024-013
Equipment Tag	500-V-510
Equipment Name	Sludge Thickener
Unit	Effluent Treatment Plant (500)
Inspection Date	2024-10-14
Inspection Type	Ultrasonic Thickness
Inspector	Pooja Bhosale (Inspection Engineer, EMP-0017)
Next Due Date	2025-04-12
Governing SOP	SOP-500-014

1. Scope

Risk-Based Inspection (RBI) assessment of 500-V-510 performed by Pooja Bhosale (Inspection Engineer, EMP-0017) in accordance with SOP-500-014 and OISD inspection guidelines.

2. Findings

Ultrasonic Thickness inspection of 500-V-510 (Sludge Thickener) on 2024-10-14 found the equipment in satisfactory condition with no reportable defects. Readings are within acceptable limits per design basis.

3. Recommendation

Continue on standard RBI interval. Next inspection due 2025-04-12.