

Maintenance Work Order — WO-2024-0079

Predictive | 200-C-202

Work Order ID	WO-2024-0079
Date	2024-09-04
Equipment Tag	200-C-202
Equipment Name	Recycle Gas Compressor
Unit	Hydrocracker Unit (200)
Type	Predictive
Assigned To	Arun Patil (Electrical Engineer, EMP-0041)
Downtime (hrs)	31.5
Cost (INR)	815,389
Status	Closed
Linked Incident	None

1. Job Description

Predictive maintenance job on 200-C-202 (Recycle Gas Compressor): oil analysis indicated contamination, oil change and filter replacement performed. Work performed by Arun Patil (Electrical Engineer, EMP-0041).

2. Safety & Isolation

Work executed under isolation per SP-004 (H2S Detection and Emergency Response). Governing operating procedure: SOP-200-004.

3. Outcome

Equipment downtime of 31.5 hours recorded. Total job cost INR 815,389. Work order status: Closed.