

Maintenance Work Order — WO-2025-0004

Corrective | 400-P-405

Work Order ID	WO-2025-0004
Date	2025-02-19
Equipment Tag	400-P-405
Equipment Name	Tank Transfer Pump
Unit	Tank Farm / Storage (400)
Type	Corrective
Assigned To	Neha Patil (Instrumentation Engineer, EMP-0038)
Downtime (hrs)	42.6
Cost (INR)	572,296
Status	Closed
Linked Incident	None

1. Job Description

Corrective maintenance job on 400-P-405 (Tank Transfer Pump): gasket replacement following flange seepage. Work performed by Neha Patil (Instrumentation Engineer, EMP-0038).

2. Safety & Isolation

Work executed under isolation per SP-005 (Working at Height on Structures and Columns). Governing operating procedure: SOP-400-012.

3. Outcome

Equipment downtime of 42.6 hours recorded. Total job cost INR 572,296. Work order status: Closed.