

Maintenance Work Order — WO-2025-0042

Corrective | 500-V-510

Work Order ID	WO-2025-0042
Date	2025-09-08
Equipment Tag	500-V-510
Equipment Name	Sludge Thickener
Unit	Effluent Treatment Plant (500)
Type	Corrective
Assigned To	Ravi Shaikh (Instrumentation Engineer, EMP-0037)
Downtime (hrs)	45.4
Cost (INR)	826,273
Status	Closed
Linked Incident	INC-2024-014

1. Job Description

Corrective maintenance job on 500-V-510 (Sludge Thickener): coupling realignment after vibration trend deviation. Work performed by Ravi Shaikh (Instrumentation Engineer, EMP-0037). This work order was raised as a direct follow-up to incident INC-2024-014.

2. Safety & Isolation

Work executed under isolation per SP-002 (Hot Work Permit and Fire Watch). Governing operating procedure: SOP-500-014.

3. Outcome

Equipment downtime of 45.4 hours recorded. Total job cost INR 826,273. Work order status: Closed.