

Maintenance Work Order — WO-2026-0019

Corrective | 100-D-103

Work Order ID	WO-2026-0019
Date	2026-06-17
Equipment Tag	100-D-103
Equipment Name	Distillation Column
Unit	Crude Distillation Unit (100)
Type	Corrective
Assigned To	Sunita Jadhav (Maintenance Engineer, EMP-0010)
Downtime (hrs)	27.8
Cost (INR)	99,511
Status	Closed
Linked Incident	None

1. Job Description

Corrective maintenance job on 100-D-103 (Distillation Column): mechanical seal replacement following observed leakage. Work performed by Sunita Jadhav (Maintenance Engineer, EMP-0010).

2. Safety & Isolation

Work executed under isolation per SP-004 (H2S Detection and Emergency Response). Governing operating procedure: SOP-100-001.

3. Outcome

Equipment downtime of 27.8 hours recorded. Total job cost INR 99,511. Work order status: Closed.