

Equipment Datasheet — 100-P-101

Centrifugal Pump | CDU Unit

Document ID	DS-100-P-101
Equipment Tag	100-P-101
Equipment Name	Centrifugal Pump
Process Unit	Crude Distillation Unit (100)
Manufacturer	BHEL
Install Date	2018-01-24
Design Pressure	52.0 barg
Design Temperature	138.2 degC
Material of Construction	Cast Iron
Criticality Rating	Medium
Governing SOP	SOP-100-001
Governing Safety Procedure	SP-005

1. Equipment Description

100-P-101 is a Centrifugal Pump installed in the Crude Distillation Unit (CDU) at PRPC. It was supplied by BHEL and commissioned on 2018-01-24. The equipment is classified as Medium criticality within the unit's reliability programme.

2. Design Basis

Design pressure is rated at 52.0 barg with a design temperature of 138.2 degC. Primary material of construction is Cast Iron, selected for compatibility with process fluid composition and corrosion allowance requirements specific to CDU service.

3. Operating & Safety References

Operation of 100-P-101 is governed by procedure SOP-100-001 (Crude Charge Pump Startup and Shutdown). Isolation and personnel safety during maintenance follow SP-005 (Working at Height on Structures and Columns).

4. Maintenance Philosophy

100-P-101 is included in the CDU rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (Medium).