

Equipment Datasheet — 100-P-107

Reflux Pump | CDU Unit

Document ID	DS-100-P-107
Equipment Tag	100-P-107
Equipment Name	Reflux Pump
Process Unit	Crude Distillation Unit (100)
Manufacturer	Forbes Marshall
Install Date	2016-12-03
Design Pressure	11.6 barg
Design Temperature	140.3 degC
Material of Construction	Carbon Steel
Criticality Rating	High
Governing SOP	SOP-100-002
Governing Safety Procedure	SP-010

1. Equipment Description

100-P-107 is a Reflux Pump installed in the Crude Distillation Unit (CDU) at PRPC. It was supplied by Forbes Marshall and commissioned on 2016-12-03. The equipment is classified as High criticality within the unit's reliability programme.

2. Design Basis

Design pressure is rated at 11.6 barg with a design temperature of 140.3 degC. Primary material of construction is Carbon Steel, selected for compatibility with process fluid composition and corrosion allowance requirements specific to CDU service.

3. Operating & Safety References

Operation of 100-P-107 is governed by procedure SOP-100-002 (Atmospheric Distillation Column Operation). Isolation and personnel safety during maintenance follow SP-010 (Fire and Gas Detection System Testing).

4. Maintenance Philosophy

100-P-107 is included in the CDU rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (High).