

Equipment Datasheet — 100-V-109

Flash Drum | CDU Unit

Document ID	DS-100-V-109
Equipment Tag	100-V-109
Equipment Name	Flash Drum
Process Unit	Crude Distillation Unit (100)
Manufacturer	Forbes Marshall
Install Date	2009-11-09
Design Pressure	127.4 barg
Design Temperature	340.8 degC
Material of Construction	Stainless Steel 316L
Criticality Rating	High
Governing SOP	SOP-100-001
Governing Safety Procedure	SP-004

1. Equipment Description

100-V-109 is a Flash Drum installed in the Crude Distillation Unit (CDU) at PRPC. It was supplied by Forbes Marshall and commissioned on 2009-11-09. The equipment is classified as High criticality within the unit's reliability programme.

2. Design Basis

Design pressure is rated at 127.4 barg with a design temperature of 340.8 degC. Primary material of construction is Stainless Steel 316L, selected for compatibility with process fluid composition and corrosion allowance requirements specific to CDU service.

3. Operating & Safety References

Operation of 100-V-109 is governed by procedure SOP-100-001 (Crude Charge Pump Startup and Shutdown). Isolation and personnel safety during maintenance follow SP-004 (H2S Detection and Emergency Response).

4. Maintenance Philosophy

100-V-109 is included in the CDU rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (High).