

Equipment Datasheet — 200-PSV-207

Reactor Relief Valve | HCU Unit

Document ID	DS-200-PSV-207
Equipment Tag	200-PSV-207
Equipment Name	Reactor Relief Valve
Process Unit	Hydrocracker Unit (200)
Manufacturer	Fluor Daniel India
Install Date	1998-12-04
Design Pressure	123.8 barg
Design Temperature	276.3 degC
Material of Construction	Duplex Stainless Steel
Criticality Rating	High
Governing SOP	SOP-200-006
Governing Safety Procedure	SP-003

1. Equipment Description

200-PSV-207 is a Reactor Relief Valve installed in the Hydrocracker Unit (HCU) at PRPC. It was supplied by Fluor Daniel India and commissioned on 1998-12-04. The equipment is classified as High criticality within the unit's reliability programme.

2. Design Basis

Design pressure is rated at 123.8 barg with a design temperature of 276.3 degC. Primary material of construction is Duplex Stainless Steel, selected for compatibility with process fluid composition and corrosion allowance requirements specific to HCU service.

3. Operating & Safety References

Operation of 200-PSV-207 is governed by procedure SOP-200-006 (High Pressure Separator Level Control). Isolation and personnel safety during maintenance follow SP-003 (Confined Space Entry - Vessels and Tanks).

4. Maintenance Philosophy

200-PSV-207 is included in the HCU rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (High).