

Equipment Datasheet — 300-MTR-306

Cooling Water Pump Motor | UTIL Unit

Document ID	DS-300-MTR-306
Equipment Tag	300-MTR-306
Equipment Name	Cooling Water Pump Motor
Process Unit	Utilities & Offsites (300)
Manufacturer	Kirloskar Brothers Ltd
Install Date	2008-10-18
Design Pressure	44.1 barg
Design Temperature	136.9 degC
Material of Construction	Carbon Steel
Criticality Rating	High
Governing SOP	SOP-300-008
Governing Safety Procedure	SP-009

1. Equipment Description

300-MTR-306 is a Cooling Water Pump Motor installed in the Utilities & Offsites (UTIL) at PRPC. It was supplied by Kirloskar Brothers Ltd and commissioned on 2008-10-18. The equipment is classified as High criticality within the unit's reliability programme.

2. Design Basis

Design pressure is rated at 44.1 barg with a design temperature of 136.9 degC. Primary material of construction is Carbon Steel, selected for compatibility with process fluid composition and corrosion allowance requirements specific to UTIL service.

3. Operating & Safety References

Operation of 300-MTR-306 is governed by procedure SOP-300-008 (Steam Turbine Generator Synchronization). Isolation and personnel safety during maintenance follow SP-009 (Crane and Heavy Lift Operations).

4. Maintenance Philosophy

300-MTR-306 is included in the UTIL rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (High).