

Equipment Datasheet — 300-P-309

Firewater Pump | UTIL Unit

Document ID	DS-300-P-309
Equipment Tag	300-P-309
Equipment Name	Firewater Pump
Process Unit	Utilities & Offsites (300)
Manufacturer	Forbes Marshall
Install Date	2011-02-04
Design Pressure	119.8 barg
Design Temperature	195.9 degC
Material of Construction	Carbon Steel
Criticality Rating	Medium
Governing SOP	SOP-300-009
Governing Safety Procedure	SP-001

1. Equipment Description

300-P-309 is a Firewater Pump installed in the Utilities & Offsites (UTIL) at PRPC. It was supplied by Forbes Marshall and commissioned on 2011-02-04. The equipment is classified as Medium criticality within the unit's reliability programme.

2. Design Basis

Design pressure is rated at 119.8 barg with a design temperature of 195.9 degC. Primary material of construction is Carbon Steel, selected for compatibility with process fluid composition and corrosion allowance requirements specific to UTIL service.

3. Operating & Safety References

Operation of 300-P-309 is governed by procedure SOP-300-009 (Cooling Tower Water Chemistry Control). Isolation and personnel safety during maintenance follow SP-001 (Lockout-Tagout (LOTO) for Rotating Equipment).

4. Maintenance Philosophy

300-P-309 is included in the UTIL rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (Medium).