

Equipment Datasheet — 300-PSV-308

Boiler Safety Valve | UTIL Unit

Document ID	DS-300-PSV-308
Equipment Tag	300-PSV-308
Equipment Name	Boiler Safety Valve
Process Unit	Utilities & Offsites (300)
Manufacturer	Sulzer India
Install Date	2004-03-24
Design Pressure	168.6 barg
Design Temperature	291.3 degC
Material of Construction	Low Alloy Steel (Cr-Mo)
Criticality Rating	Medium
Governing SOP	SOP-300-008
Governing Safety Procedure	SP-002

1. Equipment Description

300-PSV-308 is a Boiler Safety Valve installed in the Utilities & Offsites (UTIL) at PRPC. It was supplied by Sulzer India and commissioned on 2004-03-24. The equipment is classified as Medium criticality within the unit's reliability programme.

2. Design Basis

Design pressure is rated at 168.6 barg with a design temperature of 291.3 degC. Primary material of construction is Low Alloy Steel (Cr-Mo), selected for compatibility with process fluid composition and corrosion allowance requirements specific to UTIL service.

3. Operating & Safety References

Operation of 300-PSV-308 is governed by procedure SOP-300-008 (Steam Turbine Generator Synchronization). Isolation and personnel safety during maintenance follow SP-002 (Hot Work Permit and Fire Watch).

4. Maintenance Philosophy

300-PSV-308 is included in the UTIL rotating/static equipment reliability programme with scheduled preventive maintenance and risk-based inspection (RBI) intervals determined by criticality rating (Medium).