

Maintenance Work Order — WO-2025-0057

Predictive | 200-V-205

Work Order ID	WO-2025-0057
Date	2025-06-14
Equipment Tag	200-V-205
Equipment Name	High Pressure Separator
Unit	Hydrocracker Unit (200)
Type	Predictive
Assigned To	Vivek Patil (Contract Technician, EMP-0044)
Downtime (hrs)	46.8
Cost (INR)	648,378
Status	In Progress
Linked Incident	None

1. Job Description

Predictive maintenance job on 200-V-205 (High Pressure Separator): oil analysis indicated contamination, oil change and filter replacement performed. Work performed by Vivek Patil (Contract Technician, EMP-0044).

2. Safety & Isolation

Work executed under isolation per SP-002 (Hot Work Permit and Fire Watch). Governing operating procedure: SOP-200-005.

3. Outcome

Equipment downtime of 46.8 hours recorded. Total job cost INR 648,378. Work order status: In Progress.