

Maintenance Work Order — WO-2025-0080

Predictive | 500-AGT-501

Work Order ID	WO-2025-0080
Date	2025-07-20
Equipment Tag	500-AGT-501
Equipment Name	Flocculation Agitator
Unit	Effluent Treatment Plant (500)
Type	Predictive
Assigned To	Neha Khan (Instrumentation Engineer, EMP-0039)
Downtime (hrs)	36.5
Cost (INR)	596,912
Status	Closed
Linked Incident	None

1. Job Description

Predictive maintenance job on 500-AGT-501 (Flocculation Agitator): oil analysis indicated contamination, oil change and filter replacement performed. Work performed by Neha Khan (Instrumentation Engineer, EMP-0039).

2. Safety & Isolation

Work executed under isolation per SP-008 (Chemical Handling and Spill Response - ETP). Governing operating procedure: SOP-500-015.

3. Outcome

Equipment downtime of 36.5 hours recorded. Total job cost INR 596,912. Work order status: Closed.