

PLASMA SPRAY PROCESSORS Works Instruction	QF/QMS/02/23	
	Rev. 00	
	Date : 26/02/2023	

Operations/Work/Job Activity covered by this assessment: Calibration

Scope: Quality Department, Third Party Lab, Stores

Pre requisites: Labels on instruments / machines indicating no and dates

Work Instructions:

1. The Quality department will maintain and keep updated the list of measuring instruments namely QF/QA/02
2. The list includes all measuring instruments being used by production and quality departments. It also includes pressure gauges.
3. The Quality department has to be review the list every month and check for instruments that will be due for calibration within next 30 days.
4. Calibration request to be sent to the vendors to schedule the recalibration on site. Normal Leadtime for carrying out calibration is 2 weeks.
5. Operators, Stores person need to be informed of the upcoming calibration schedule.
6. Operators, Stores person also to be instructed to stop using past their calibration date.
7. The overdue instruments are to be returned to stores department and issue of same to be resumed only after recalibration.

Assessor :		Signature:		Date:	
Approved:		Signature:		Date:	