

CONFIDENTIAL - NORTH PLANT ENGINEERING LOG

Log ID: EL-2026-0312-A

Event Timestamp: 2026-03-12 14:22:00 UTC

Incident: Secondary Bund Valve Failure

Details:

- Primary containment line-4 ruptured during solvent transfer.
- Secondary bund containment valves were manually locked open.
- Approx. 50,000 gallons of toxic solvent drained into soil.
- Flow logs verify immediate drainage into Willow Creek.