

| Return Duct Schedule | | | | | | |
|--|--------|-------|--------|------------|--|--|
| Family and Type | Height | Width | Length | Flow | | |
| De star and an Drest Element I De dive De mit / Oh en Dremeh | 200 | 075 | 0007 | 500 0 L /- | | |
| Rectangular Duct: Flanged Radius Bend / Shoe Branch | 300 | 375 | 2307 | 560.0 L/s | | |
| Rectangular Duct: Flanged Radius Bend / Shoe Branch | 300 | 375 | 1397 | 560.0 L/s | | |
| Rectangular Duct: Flanged Radius Bend / Shoe Branch | 300 | 275 | 2463 | 400.0 L/s | | |
| Rectangular Duct: Flanged Radius Bend / Shoe Branch | 275 | 250 | 1163 | 320.0 L/s | | |
| Rectangular Duct: Flanged Radius Bend / Shoe Branch | 225 | 225 | 1172 | 240.0 L/s | | |
| Rectangular Duct: Flanged Radius Bend / Shoe Branch | 200 | 175 | 1855 | 160.0 L/s | | |
| Rectangular Duct: Flanged Radius Bend / Shoe Branch | 200 | 175 | 300 | 160.0 L/s | | |
| Rectangular Duct: Flanged Radius Bend / Shoe Branch | 140 | 125 | 1872 | 80.0 L/s | | |
| Rectangular Duct: Flanged Radius Bend / Shoe Branch | 140 | 125 | 1708 | 80.0 L/s | | |
| Rectangular Duct: Flanged Radius Bend / Shoe Branch | 140 | 125 | 1030 | 80.0 L/s | | |
| Rectangular Duct: Flanged Radius Bend / Shoe Branch | 140 | 125 | 968 | 80.0 L/s | | |
| Rectangular Duct: Flanged Radius Bend / Shoe Branch | 140 | 125 | 955 | 80.0 L/s | | |
| Rectangular Duct: Flanged Radius Bend / Shoe Branch | 140 | 125 | 943 | 80.0 L/s | | |

| Return Duct Fitting Schedule | | | | | |
|--|-----------------|-------|--|--|--|
| Family and Type | Size | Count | | | |
| Rectangular Union: Standard | 375x300-375x300 | 1 | | | |
| Rectangular Shoe Branch - Flanged: Standard | 175x200-175x200 | 1 | | | |
| Rectangular Shoe Branch - Flanged: Standard | 125x140-125x140 | 4 | | | |
| Rectangular Medium Radius Bend - Flanged: Standard | 175x200-175x200 | 1 | | | |
| Rectangular Medium Radius Bend - Flanged: Standard | 125x140-125x140 | 1 | | | |
| Rectangular Concentric Taper - Flanged: Standard | 375x300-275x300 | 1 | | | |
| Rectangular Concentric Taper - Flanged: Standard | 275x300-250x275 | 1 | | | |
| Rectangular Concentric Taper - Flanged: Standard | 250x275-225x225 | 1 | | | |
| Rectangular Concentric Taper - Flanged: Standard | 225x225-125x140 | 1 | | | |
| Rectangular - Round Transformation - Flanged: Standard | 300x300-200ø | 1 | | | |
| Rectangular - Round Transformation - Flanged: Standard | 300x300-150ø | 5 | | | |
| Rectangular - Round Transformation - Flanged: Standard | 175x200-200ø | 1 | | | |
| Rectangular - Round Transformation - Flanged: Standard | 150ø-125x140 | 5 | | | |



www.lit.ie

Educational Exercise Not for Construction

Owner

Revit MEP

Return System

| Checked by Checker H-103 | | | | | | |
|--------------------------|-------------------|------------|--|--|--|--|
| Drawn b | у | Author | | | | |
| Date | | Issue Date | | | | |
| Project r | ect number RMEP02 | | | | | |

Scale

10 80.0 L/s 80.0 L/s 125x140— —125x140 —125x140 375x300 375×300 275x300 250x275 225x225 ___175x200 125x140-

2 0 - Return System Parts
1:50

1 : 50