







PLAN  
R.C. SLAB INFILL PANEL ON EXISTING FIRST FLOOR



PLAN  
R.C. SLAB INFILL PANEL ON EXISTING FIRST FLOOR



TYPICAL ELEVATION  
R.C. SLAB INFILL PANEL  
STEEL SUPPORT ANGLE DETAIL



SECTION A - A

## NOTES

- ALL LEVELS AND DIMENSIONS TO BE CHECKED ON SITE.
- THIS DRAWING TO BE READ IN CONJUNCTION WITH THE ARCHITECTURAL DRAWINGS.
- ALL CONCRETE WORK TO COMPLY WITH SABS 1200G.
- CONCRETE CLASS :-
  - PILECAPS & GROUND BEAMS = 25 MPa
  - STRIP FOOTINGS & BASES = 25 MPa
  - COLUMNS, SHEAR & LIFT WALLS = 30 MPa
  - SLABS, BEAMS & STAIRCASES = 25 MPa
  - RETAINING WALLS = 25 MPa
  - SURFACE BEDS = 30 MPa
  - BLINDING = 10 MPa
- COVER TO REINFORCEMENT :-  
AS INDICATED ON DRAWING
- ALL FOUNDATION EXCAVATIONS TO BE INSPECTED BY THE ENGINEER PRIOR TO CASTING OF CONCRETE.
- ALL REINFORCING FIXING TO BE INSPECTED BY THE ENGINEER PRIOR TO CASTING OF CONCRETE.
- SIX CUBES TO BE TAKEN PER POUR.  
THREE TO BE TESTED AT SEVEN DAYS, THE REMAINDER AT TWENTY EIGHT DAYS. THE RESULTS TO BE FORWARDED TO THE ENGINEER.
- CONTRACTOR TO CONSTRUCT A BLINDING LAYER IF SOIL CONDITIONS RESULT IN REINFORCEMENT COVER NOT BEING MAINTAINED.
- ALL STRUCTURAL CONCRETE TO BE CURED FOR A MINIMUM OF FIVE DAYS.
- BRICKWORK SHOWN HATCHED ARE LOAD BEARING. ALL LOAD BEARING BRICKWORK TO BE 14MPa NPL TOP OF ALL BRICKWORK TO RECEIVE 2 LAYERS OF 3 PLY MALTHOID ON SMOOTH RENDERED SURFACE.
- ALL SINGLE SKIN BRICKWORK TO BE STOPPED 2 COURSES BELOW SOFFIT OF SLAB AND COMPLETED AFTER PROPS HAVE BEEN REMOVED.
- ALL CONCRETE PLASTER AND BRICKWORK PLASTER INTER-FACES TO RECEIVE V-JOINTS.
- THE ENGINEER REQUIRES 24HRS NOTICE FOR ALL INSPECTIONS.

| REV | DESCRIPTION         | BY   | DATE       |
|-----|---------------------|------|------------|
| T1  | FOR TENDER PURPOSES | S.A. | 24/06/2020 |

professional person M.NAIR P.TechEng  
registration 200570211

PROJECT MANAGER / PRINCIPAL AGENT



CLIENT



PROJECT

UMALUSI OFFICES  
ADDITIONS AND ALTERATIONS

DETAILS

EXISTING MAIN BUILDING  
NEW R.C. SLAB INFILL PANELS  
ON THE EXISTING FIRST FLOOR SLAB  
STRUCTURAL LAYOUT & DETAILS



SUITE 106, EBBENVIEW BUILDING, STRATHMORE PARK,  
305 KILIMBARE ROAD, DURBAN 4051  
e-mail: info@mapafrica.co.za  
FAX (031) 3062929 TEL (031) 3066581

|          |      |                    |           |
|----------|------|--------------------|-----------|
| DESIGNED | K.L. | COPYRIGHT RESERVED | SCALES    |
| DRAWN    | K.L. | PL                 | 1:25 1:10 |
| APPROVED | M.N. | DATE 30/01/2020    |           |

DRAWING No. 200-309 / 304 REV T1

FOR TENDER PURPOSES