## Subtype Intelligent Inverter Heat Pump 20-R32

| | |
|---|---|
| Certificate Holder | Guangdong PHNIX Eco-Energy Solution Ltd. |
| Address | No. 3 Tianyuan Road Dagang Town |
| ZIP | 511470 |
| City | Guangdong |
| Country | CN |
| Certification Body | BRE |
| Subtype title | Intelligent Inverter Heat Pump 20-R32 |
| Registration number | 041-K020-01 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R32 |
| Mass of Refrigerant | 1.1 kg |
| Certification Date | 01.11.2021 |
| Testing basis | Heat Pump Keymark Scheme Rules Rev 09 |
| Testing laboratory | TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN |



This information was generated by the HP KEYMARK database on 02.10.2026

| Model PASRW020-BP-PS-B | | |
|---|---|---|
| Model name | PASRW020-BP-PS-B | |
| Application | Heating (medium temp) | |
| Units | Outdoor | |
| Climate zone (for heating) | n/a | |
| Reversibility | Yes | |
| Cooling mode application (optional) | n/a | |
| Any additional heat sources | n/a | |

| General data | | |
|---|---|---|
| Power supply | 1x230V 50Hz | |
| Off-peak product | n/a | |

| Outdoor Air/Water | | |
|---|---|---|
| EN 14511-4 \| Heating | | |
| Shutting off the heat transfer medium flow | passed | |
| Complete power supply failure | passed | |
| Defrost test | passed | |
| Starting and operating test | passed | |

| EN 14511-2 \| Heating | | |
|---|---|---|
| | Low temperature | Medium temperature |
| Heat output | 5.99 kW | 5.13 kW |
| El input | 1.21 kW | 1.87 kW |
| COP | 4.97 | 2.74 |

| EN 12102-1 \| Average Climate | | |
|---|---|---|
| | Low temperature | Medium temperature |
| Sound power level outdoor | 55 dB(A) | 58 dB(A) |

| EN 14825 \| Average Climate | | |
|---|---|---|
| | Low temperature | Medium temperature |
| ηs | 187 % | 130 % |
| Prated | 5.29 kW | 5.00 kW |
| SCOP | 4.75 | 3.33 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 4.68 kW | 5.00 kW |
| COP Tj = -7°C | 3.28 | 2.20 |
| Cdh Tj = -7 °C | 0.990 | 0.990 |
| Pdh Tj = +2°C | 2.86 kW | 3.09 kW |
| COP Tj = +2°C | 4.52 | 3.26 |
| Cdh Tj = +2 °C | 0.990 | 0.990 |
| Pdh Tj = +7°C | 2.45 kW | 2.73 kW |



This information was generated by the HP KEYMARK database on 02.10.2026

| | | |
|---|---|---|
| COP Tj = +7°C | 5.87 | 4.03 |
| Cdh Tj = +7 °C | 0.990 | 0.990 |
| Pdh Tj = 12°C | 2.85 kW | 2.70 kW |
| COP Tj = 12°C | 8.72 | 6.34 |
| Cdh Tj = +12 °C | 0.990 | 0.990 |
| Pdh Tj = Tbiv | 4.68 kW | 5.00 kW |
| COP Tj = Tbiv | 3.28 | 2.20 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 4.92 kW | 4.33 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.79 | 1.71 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.990 | 0.990 |
| WTOL | 53 °C | 53 °C |
| Poff | 13 W | 13 W |
| PTO | 13 W | 13 W |
| PSB | 13 W | 13 W |
| PCK | 43 W | 43 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.38 kW | 1.32 kW |
| Annual energy consumption Qhe | 2302 kWh | 3503 kWh |



This information was generated by the HP KEYMARK database on 02.10.2026