## Subtype Intelligent Inverter Heat Pump 60-R290

| | |
|---|---|
| Certificate Holder | Guangdong PHNIX Eco-Energy Solution Ltd. |
| Address | No. 3 Tianyuan Road Dagang Town |
| ZIP | 511470 |
| City | Guangdong |
| Country | CN |
| Certification Body | BRE |
| Subtype title | Intelligent Inverter Heat Pump 60-R290 |
| Registration number | 041-K020-06 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R290 |
| Mass of Refrigerant | 1.3 kg |
| Certification Date | 22.06.2022 |
| Testing basis | Heat Pump Keymark Scheme Rules Rev 09 |
| Testing laboratory | TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN |



This information was generated by the HP KEYMARK database on 02.10.2026

| Model PASRW060-BP-PS-D | |
|---|---|
| Model name | PASRW060-BP-PS-D |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

| General data | |
|---|---|
| Power supply | 1x230V 50Hz |
| Off-peak product | n/a |

| Outdoor Air/Water | |
|---|---|
| EN 14511-4 \| Heating | |
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

| EN 14511-2 \| Heating | | |
|---|---|---|
| | Low temperature | Medium temperature |
| Heat output | 16.99 kW | 17.36 kW |
| El input | 3.61 kW | 5.44 kW |
| COP | 4.71 | 3.19 |

| EN 12102-1 \| Average Climate | | |
|---|---|---|
| | Low temperature | Medium temperature |
| Sound power level outdoor | 64 dB(A) | 64 dB(A) |

| EN 14825 \| Average Climate | | |
|---|---|---|
| | Low temperature | Medium temperature |
| ηs | 183 % | 145 % |
| Prated | 12.57 kW | 11.81 kW |
| SCOP | 4.65 | 3.71 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 11.12 kW | 10.45 kW |
| COP Tj = -7°C | 3.31 | 2.31 |
| Cdh Tj = -7 °C | 0.990 | 0.990 |
| Pdh Tj = +2°C | 6.82 kW | 6.39 kW |
| COP Tj = +2°C | 4.51 | 3.64 |
| Cdh Tj = +2 °C | 0.990 | 0.990 |
| Pdh Tj = +7°C | 7.60 kW | 7.44 kW |



This information was generated by the HP KEYMARK database on 02.10.2026

| | | |
|---|---|---|
| COP Tj = +7°C | 5.60 | 4.68 |
| Cdh Tj = +7 °C | 0.990 | 0.990 |
| Pdh Tj = 12°C | 7.71 kW | 7.56 kW |
| COP Tj = 12°C | 6.89 | 6.18 |
| Cdh Tj = +12 °C | 0.990 | 0.990 |
| Pdh Tj = Tbiv | 11.12 kW | 10.45 kW |
| COP Tj = Tbiv | 3.31 | 2.31 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 12.54 kW | 12.00 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.85 | 1.96 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.990 | 0.990 |
| WTOL | 75 °C | 75 °C |
| Poff | 11 W | 11 W |
| PTO | 11 W | 11 W |
| PSB | 11 W | 11 W |
| PCK | 58 W | 58 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.03 kW | 0.00 kW |
| Annual energy consumption Qhe | 5587 kWh | 6587 kWh |



This information was generated by the HP KEYMARK database on 02.10.2026

## Model PASRW060S-BP-PS-D

| | |
|---|---|
| Model name | PASRW060S-BP-PS-D |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

## General data

| | |
|---|---|
| Power supply | 3x400V 50Hz |
| Off-peak product | n/a |

## Outdoor Air/Water

### EN 14511-4 | Heating

| | |
|---|---|
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

### EN 14511-2 | Heating

| | Low temperature | Medium temperature |
|---|---|---|
| Heat output | 15.73 kW | 17.03 kW |
| El input | 3.94 kW | 4.79 kW |
| COP | 3.99 | 3.56 |

### EN 12102-1 | Average Climate

| | Low temperature | Medium temperature |
|---|---|---|
| Sound power level outdoor | 62 dB(A) | 61 dB(A) |

### EN 14825 | Average Climate

| | Low temperature | Medium temperature |
|---|---|---|
| ηs | 193 % | 145 % |
| Prated | 12.55 kW | 12.34 kW |
| SCOP | 4.91 | 3.70 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 11.11 kW | 10.92 kW |
| COP Tj = -7°C | 3.23 | 2.34 |
| Cdh Tj = -7 °C | 0.990 | 0.990 |
| Pdh Tj = +2°C | 6.89 kW | 6.80 kW |
| COP Tj = +2°C | 4.83 | 3.58 |
| Cdh Tj = +2 °C | 0.990 | 0.990 |
| Pdh Tj = +7°C | 7.30 kW | 7.36 kW |



This information was generated by the HP KEYMARK database on 02.10.2026

| | | |
|---|---|---|
| COP Tj = +7°C | 6.04 | 4.74 |
| Cdh Tj = +7 °C | 0.990 | 0.990 |
| Pdh Tj = 12°C | 7.78 kW | 7.39 kW |
| COP Tj = 12°C | 7.46 | 6.12 |
| Cdh Tj = +12 °C | 0.990 | 0.990 |
| Pdh Tj = Tbiv | 11.11 kW | 10.92 kW |
| COP Tj = Tbiv | 3.23 | 2.34 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 12.61 kW | 12.33 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.89 | 2.06 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.990 | 0.990 |
| WTOL | 63 °C | 63 °C |
| Poff | 11 W | 11 W |
| PTO | 11 W | 11 W |
| PSB | 11 W | 11 W |
| PCK | 17 W | 17 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 0.00 kW | 0.01 kW |
| Annual energy consumption Qhe | 5281 kWh | 6895 kWh |



This information was generated by the HP KEYMARK database on 02.10.2026