## Subtype Intelligent Inverter Heat Pump-R290-PASRW080SB-BP-PS-D

| | |
|---|---|
| Certificate Holder | Guangdong PHNIX Eco-Energy Solution Ltd. |
| Address | No. 3 Tianyuan Road Dagang Town |
| ZIP | 511470 |
| City | Guangdong |
| Country | CN |
| Certification Body | BRE |
| Subtype title | Intelligent Inverter Heat Pump-R290-PASRW080SB-BP-PS-D |
| Registration number | 041-K020-23 |
| Heat Pump Type | Outdoor Air/Water |
| Refrigerant | R290 |
| Mass of Refrigerant | 1.8 kg |
| Certification Date | 14.07.2025 |
| Testing basis | HP KEYMARK certification scheme rules rev. no.15 |
| Testing laboratory | TÜV SÜD Certification and Testing Co., Ltd. Guangzhou Branch, CN |



This information was generated by the HP KEYMARK database on 02.10.2026

| Model PASRW080SB-BP-PS-D | |
|---|---|
| Model name | PASRW080SB-BP-PS-D |
| Application | Heating (medium temp) |
| Units | Outdoor |
| Climate zone (for heating) | n/a |
| Reversibility | Yes |
| Cooling mode application (optional) | n/a |
| Any additional heat sources | n/a |

| General data | |
|---|---|
| Power supply | 3x400V 50Hz |
| Off-peak product | n/a |

| Outdoor Air/Water | |
|---|---|
| EN 14511-4 \| Heating | |
| Shutting off the heat transfer medium flow | passed |
| Complete power supply failure | passed |
| Defrost test | passed |
| Starting and operating test | passed |

| EN 14511-2 \| Heating | | |
|---|---|---|
| | Low temperature | Medium temperature |
| Heat output | 19.67 kW | 19.96 kW |
| El input | 4.45 kW | 7.65 kW |
| COP | 4.42 | 2.61 |

| EN 12102-1 \| Average Climate | | |
|---|---|---|
| | Low temperature | Medium temperature |
| Sound power level outdoor | 63 dB(A) | 66 dB(A) |

| EN 14825 \| Average Climate | | |
|---|---|---|
| | Low temperature | Medium temperature |
| ηs | 186 % | 136 % |
| Prated | 19.76 kW | 17.23 kW |
| SCOP | 4.71 | 3.49 |
| Tbiv | -7 °C | -7 °C |
| TOL | -10 °C | -10 °C |
| Pdh Tj = -7°C | 17.48 kW | 15.24 kW |
| COP Tj = -7°C | 2.90 | 2.31 |
| Cdh Tj = -7 °C | 0.900 | 0.900 |
| Pdh Tj = +2°C | 10.73 kW | 9.41 kW |
| COP Tj = +2°C | 4.69 | 3.45 |
| Cdh Tj = +2 °C | 0.900 | 0.900 |
| Pdh Tj = +7°C | 8.35 kW | 7.92 kW |



This information was generated by the HP KEYMARK database on 02.10.2026

| | | |
|---|---|---|
| COP Tj = +7°C | 6.38 | 4.52 |
| Cdh Tj = +7 °C | 0.900 | 0.900 |
| Pdh Tj = 12°C | 9.25 kW | 9.12 kW |
| COP Tj = 12°C | 7.87 | 5.93 |
| Cdh Tj = +12 °C | 0.900 | 0.900 |
| Pdh Tj = Tbiv | 17.48 kW | 15.24 kW |
| COP Tj = Tbiv | 2.90 | 2.31 |
| Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 18.76 kW | 17.05 kW |
| COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh | 2.48 | 1.97 |
| Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh | 0.900 | 0.900 |
| WTOL | 75 °C | 75 °C |
| Poff | 16 W | 16 W |
| PTO | 16 W | 16 W |
| PSB | 16 W | 16 W |
| PCK | 86 W | 86 W |
| Supplementary Heater: Type of energy input | Electricity | Electricity |
| Supplementary Heater: PSUP | 1.00 kW | 0.19 kW |
| Annual energy consumption Qhe | 8661 kWh | 10215 kWh |



This information was generated by the HP KEYMARK database on 02.10.2026