



注：除平面标注外均为S线型

报警总线 S	NH-RVS-2x1.0 JDG20 WC CC
联动总线S+D	NH-RVS-2x1.5+NH-BVR-2x2.5 JDG20 WC CC
DC24V 电源线 D (支线)	NH-BVR-2x2.5 JDG20 WC CC
DC24V 电源线 D1 (干线)	NH-BVR-2x4.0 JDG20 WC CC
消防电话总线F	ZR-RVVP-2X1.5 JDG20 WC CC
消防广播总线BC	ZR-BVR-2X1.5 JDG20 WC CC
显示盘通信总线S2	ZR-RVVP-2x1.5 JDG25 WC CC
集中控制型应急照明系统通讯总线TX	WDZN-RVSP-2x1.5-JDG20



1:100