CHUNK_ID: pneumatic-diagnostic-matrix
TITLE: Pneumatic supply alarm: pressure, flow and safety differentiation
ORIGIN: ENGINEERING_SCENARIO
SOURCE: AgenticMOM - Demo.pdf p.4; authored diagnostic profile for Festo runtime simulation

CONTENT
Scope: this engineering-authored guide applies to the runtime simulation profile for the selected Festo instance, not the physical 381 PLC alarm mapping. Press.Fault01 indicates low supply pressure for this profile. Read Press.PressureBar, Press.FlowLMin and Safety.EmergencyStop together. Normal reference is 6.0 bar and 12 litres/minute at idle. Below 4.8 bar with flow above 30 litres/minute and EmergencyStop false supports an open vent valve or pneumatic leakage hypothesis. It does not distinguish an intentionally opened valve from a damaged connector. Low pressure with low flow instead suggests insufficient upstream supply. EmergencyStop true requires a safety-stop assessment; do not interpret it as proof of leakage. Press.Ready can change independently of Turning.Ready. Alarm bits alone cannot establish root cause. Values are authored scenario engineering assumptions, not manufacturer limits.
END CONTENT

CHUNK_ID: pneumatic-maintenance-plan
TITLE: Pneumatic fault inspection and maintenance planning
ORIGIN: ENGINEERING_SCENARIO
SOURCE: AgenticMOM - Demo.pdf pp.5-6; authored maintenance planning procedure

CONTENT
Preserve alarm timestamps, pressure/flow values and the affected asset identity. Ask qualified onsite personnel to assess the air supply, valve state and connections using the site’s approved isolation procedure. Do not remotely manipulate valves, reset interlocks or start machines. Reserve an initial 30-minute inspection allowance; actual duration and spare parts depend on inspection findings. Create a corrective Maintenance Event for the MES line referenced by ProductionContext, citing the fault event and this guide. Propose a start time relative to the current clock, not the presentation date. Preview and obtain approval before creating; verify the returned event ID by reading it back. An event is a business record, not proof of physical repair. Examine affected/upcoming orders and capacity; preview any feasible rescheduling separately and obtain approval, then verify schedule and change list. Never assume maintenance creation automatically blocks orders or changes scheduling.
END CONTENT