COUNTY OF RIVERSIDE

TRANSPORTATION AND LAND MANAGEMENT AGENCY

Transportation Department

Patricia Romo, P.E.
Director of Transportation

MEMORANDUM

Date:	January 11, 2024
To:	Mark Hughes, Transportation Department Kathleen Mitchell, Planning Department
Project Number:	**CUP230002**
Project Name:	**Garden Cemetery**
Landscape Submittal:	**Landscape Concept Plan – 2nd**
Bluebeam Session:	**065-888-348**
Landscape Plans Examiner:	Annell Marquez Evora, Young Chang, (951) 955 - 0924, (951) 955-0605 amevora@rivco.org, ychang@rivco.org, marhughe@rivco.org
Recommendation:	**Resubmittal Required**

The Riverside County Transportation Department has completed the Landscape review of the above-mentioned project. This is a conceptual level review and does not compromise full approval of final design details.

1. Major comments are summarized herein. Additional detail is provided in Bluebeam on redlines and check list. Re-submittal must include a written response to comments as well as redlines and check list. **Re-submittals without these items may be delayed.**
2. Update the Historic ETo on MAWA / ETWU calculation to 57.33.
3. Provide trees in the frontage of the project along the driveway access. Refer to Fuel Modification Plans for required spacing within each zone.
4. Indicate and label right-of-way (ROW), sidewalk, and curb on plans. See Redlines. **(2ND REQUEST)**
5. At planter islands adjacent to parking spaces, show 12" wide concrete walkway strip adjacent to the curb and label. See Redlines. **(2ND REQUEST)**
6. Please expand the shrubs at the basin bottom to cover the inlets & outlets. See Redlines.
7. What is the area in color brown along the internal streets? Label.
8. Remove Hydroseed Mix from planting legend.
    a. Recommendations for slope planting are as follow(s):
        - 4:1 Slopes
            - 5-15 gallon trees & 1-5 gallon shrubs
        - 2:1 Slopes
            - 15-24 gallon trees & 1-5 gallon shrubs

    Please abide to Building & Safety Erosion Control Standards - Over 3 feet vertical - Groundcover plant material maximum 12" on center. Over 15 feet vertical – shrubs maximum 10' on center, trees 20' maximum on center, or a combination thereof.

9. **ITEMS REQUIRED FOR NEXT SUBMITTAL:**
    a. Revised Landscape Concept Plan, with corrections, (1 single PDF file of all landscape sheets)
    b. Response to comments memo (1 separate PDF file)

END MEMO

4080 Lemon Street, 8th Floor · Riverside, CA 92501 · (951) 955-6740
P.O. Box 1090 · Riverside, CA 92502-1090 · FAX (951) 955-3198

4080 Lemon Street, 8th Floor · Riverside, CA 92501 · (951) 955-6740
P.O. Box 1090 · Riverside, CA 92502-1090 · FAX (951) 955-3198