



Fw: Dinuba Street Corridor Project

From Jason Watts <jasonw@4-creeks.com>

Date Thu 11/13/2025 10:35 AM

To Jahmarra Coleman <jahmarrac@4-creeks.com>; Trevor Brooks <trevorb@4-creeks.com>; Maggie Navarrete <maggie@4-creeks.com>; Derek Nelson <derekn@4-creeks.com>

**Jason Watts**

Principal Civil Engineer / Municipal Market Sector Lead

Email: jasonw@4-creeks.com

Office: (559) 802-3052

Mobile: (559) 392-5618

Website: 4-creeks.com



From: Curtis Short <cshort@avisoninc.com>

Sent: Thursday, November 13, 2025 10:26 AM

To: Jason Watts <jasonw@4-creeks.com>

Subject: Dinuba Street Corridor Project

Jason,

We finished the takeoff on the project bidding next week and noticed some discrepancies/ ambiguities that I wanted to bring to your attention.

- The legend on the Kamm sheets says the section is 7" HMA over 8.5" AB. The cross section on sheet X1 shows 3" HMA over 8" AB.
- The legend on College Ave doesn't say anything, but the cross section on sheet X2 shows 4" HMA over 5" AB.
- The legend on the demo and layout sheets refer to sheet numbers that I can't find (i.e. AA2, AA5, L15-L19, etc.)
- The plans don't show any AC patching at the median curbs where the road is not getting reconstructed. Do we assume a 12" wide by 7" thick plug?
- The legends for College and El Monte don't specify the hatching, but I'm assuming it's a 3" overlay as shown on the Kamm sheets.
- The quantities in the legend on the Kamm sheets for reconstruct or overlay don't jive with anything that I can tell.
- There is no demo shown for the medians on the El Monte demo sheets.
- The demo on College says remove 15.5", but if the structural section for College is 11", why is 15.5" being removed?
- Some of the bid quantities appear to be incorrect (i.e. sawcut, curb & gutter, sidewalk). Depending on what the structural sections are for the AB and AC, those might be off.

Curtis W. Short

[Avison Construction, Inc.](#)

11/13/25, 11:09 AM

Inbox - Jahmarra Coleman - Outlook

40434 Brickyard Drive

Madera, CA 93636

Office Phone: 559-431-0317

Office Fax: 559-431-0321

