



Fw: 2025 Corridor Improvements Project

From Jason Watts <jasonw@4-creeks.com>
Date Thu 11/6/2025 12:06 PM
To Jahmarra Coleman <jahmarrac@4-creeks.com>

FYI

 [4Creeks Logo - Black H 100ESOP.png](#)

Jason Watts

Principal Civil Engineer / Municipal Market Sector Lead

Email: jasonw@4-creeks.com

Office: (559) 802-3052

Mobile: (559) 392-5618

Website: 4-creeks.com

From: jose.ruvalcaba@terrawestconstruction.com <jose.ruvalcaba@terrawestconstruction.com>
Sent: Thursday, November 6, 2025 12:00 PM
To: Jason Watts <jasonw@4-creeks.com>
Cc: 'Ramon Medina' <ramon.medina@terrawestconstruction.com>
Subject: 2025 Corridor Improvements Project

Jason,

I have the following questions:

- Sheet L1 calls for the proposed pavement section to be 7"HMA over 8.5"AB for Kamm Avenue. However, detail sheet X1 for Kamm Avenue the detail shows a proposed pavement section of 3"HMA over 8"AB. Can you please clarify the correct section for Kamm Avenue.
- Per detail sheet X2 the proposed pavement section for College Avenue is 4"HMA over 5"AB. Please confirm this correct as Sheets L6 though L8 do not have a proposed asphalt legend section and the hatch is the same as Kamm Avenue.
- There is a bid item for the Pavement Reinforcing Mat. Please provide a detail to include the pavement reinforcing mat in it.

Thank you.

Jose Ruvalcaba, CESSWI, QSP
Project Manager

Terra West Construction, Inc.
Mobile: (559) 321-1630
Fax: (559) 390-0483

11/13/25, 10:07 AM

240085 Corridor - Jahmarra Coleman - Outlook

1030 Gettysburg Avenue, Suite 107
Clovis, CA 93612

California License No. 924631
DIR Number: 1000712658
DBE Number: 48176
SBE Number: 2015847

