

Annual HVAC Service

Report · March 12, 2026

Annual preventative maintenance – cooling season

Unit: Trane XR14, installed 2019, serial 19143K8821

Refrigerant charge: within spec

Condenser coil cleaned; capacitor tested at 44.8 uF (rated 45)

Blower wheel cleaned, filter replaced (20x25x1 MERV 11)

Result: PASS. Next service due March 2027.

Technician: R. Alvarez, TACLB #44219E