

BHARAT HEALTH INFRASTRUCTURE MISSION
TENDER NOTICE: SUPPLY OF DIESEL GENERATOR SETS

SECTION 1: SCOPE OF SUPPLY

The contractor shall supply 20 units of 125 kVA Silent Diesel Generator Sets for Community Health Centers.
Operating Voltage: 415 V, 3-Phase, 50 Hz. Fuel consumption shall not exceed 28 liters per hour at 100% load.

BHARAT HEALTH INFRASTRUCTURE MISSION
TENDER NOTICE: SUPPLY OF DIESEL GENERATOR SETS

SECTION 2: TECHNICAL SPECIFICATIONS & STANDARDS

The engine shall conform to IS 10000 or relevant ISO standard.

Alternator shall conform to IS 13364 (Part 2).

Noise level shall be less than 75 dBA at 1 meter.

All equipment shall carry standard warranty of 24 months.

BHARAT HEALTH INFRASTRUCTURE MISSION
TENDER NOTICE: SUPPLY OF DIESEL GENERATOR SETS

SECTION 3: TESTING AND INSPECTION

Type tests and routine tests shall be carried out at manufacturer works.
Routine test certificates must be provided before dispatch.