



Environmental Quality Rating

Based on 6 readings over the specified period

Average Metrics

Temperature

31.7°C

Humidity

38.0%

CO<sub>2</sub> Level

12 ppm

Occupancy

0.6

KPIv (Ventilation Quality Index)

0.00

Lower values indicate better ventilation

Min/Max Values

Metric	Minimum	Maximum	Range
Temperature (°C)	31.0	32.0	1.0
Humidity (%)	36.0	40.0	4.0
CO <sub>2</sub> (ppm)	11	13	2
KPIv	0.00	0.00	0.00

## Recommendations

---

- Adjust temperature to optimal range (20-26°C). Current: 31.7°C.
- Maintain humidity between 40-60%. Current: 38.0%.

Generated on April 11, 2025 | Classroom Monitoring System