

No. Dok. : FM-LAP- D2-SOP-003-010	Formulir Preventive Maintenance Battery	
Versi : 1.0		
Hal : 1 dari 2		
Label : Internal		

Location : Cikarang Trade Center
 Date / time : 20 Juli 2025
 Battery Temperature : 24
 Battery Bank : 2

Bank : 1 UPS						Bank : 1 Recti					
Battery Type : Baterai Kering UPS						Battery Type : Baterai Kering Recti					
Battery Brand : Ritar						Battery Brand : Ritar					
End Device Batt : 65 AH						End Device Batt : 65 AH					
No	Voltage	SOH	No	Voltage	SOH	No	Voltage	SOH	No	Voltage	SOH
1	12,5	83	11			1	12,7	85	11		
2	12,4	74	12			2	12,5	85	12		
3	12,5	72	13			3	12,6	70	13		
4	12,5	75	14			4	12,5	80	14		
5	12,5	70	15			5			15		
6	12,7	80	16			6			16		
7	12,4	50	17			7			17		
8	12,8	70	18			8			18		
9			19			9			19		
10			20			10			20		

Bank :						Bank :					
Battery Type :						Battery Type :					
Battery Brand :						Battery Brand :					
End Device Batt :						End Device Batt :					
No	Voltage	SOH	No	Voltage	SOH	No	Voltage	SOH	No	Voltage	SOH
1			11			1			11		
2			12			2			12		
3			13			3			13		
4			14			4			14		
5			15			5			15		
6			16			6			16		
7			17			7			17		
8			18			8			18		
9			19			9			19		
10			20			10			20		

* Measurement with load test (backup test UPS /Rectifier)
 * Standard min 12 VDC/Battery
 * Standard SOH 80%

No. Dok. : FM-LAP- D2-SOP-003-010	Formulir Preventive Maintenance Battery	
Versi : 1.0		
Hal : 2 dari 2		
Label : Internal		

No.	Descriptions	Result	Operational Standard	Status (OK/NOK)
1.	Rectifier Switching test, from the main source (PLN) to back up mode, by turning off Rectifier input MCB	Normal		OK
	a. Battery voltage (on Backup Mode).	Normal		OK
	b. Measurement I (at the beginning)	50	Min 49 VDC	OK
	c. Measurement II (15 th minutes)	52,5	Min 48 VDC	OK

Notes / additional informations :

<u>Baterai Normal</u> <u>Tanggal Produksi battery 1 = 10/09/2021</u> <u>Tanggal Produksi battery 2 = 10/08/2021</u> <u>Baterai 2 berumur 5 tahun</u>
--

Executor				Verifikator (_____) (_____)	Head Of Sub Departement
No	Nama	Mitra / Internal	Signature		
1	ADI	IMS			
2	Zikir	IMS			
3					
4					