

No. Dok. : FM-LAP- D2-SOP-003-005	Formulir Preventive Maintenance Inverter -48VDC/220VAC	
Versi : 1.0		
Hal : 1 dari 1		
Label : Internal		

Location : Grand Mall Bekasi
 Date / time : Sabtu, 31 Januari 2025
 Brand / Type : Matrik
 Reg. Number : -
 S/N : 126721651256

No.	Descriptions	Result	Operational Standard	Status (OK/NOK)
1.	Physical Check			
	a. Environment Condition	Clean	Clean, No dust	OK
	b. LED / display *)	Normal	Normal	OK
2.	Performance and Capacity Check			OK
	a. DC Input Voltage	52,9	48 - 56 VDC	OK
	b. DC Current Input *)	1,01	≤ 9 A (500 VA)	OK
			≤ 16 A (1000 VA)	
			≤ 33 A (2000 VA)	
	c. AC Current Output *)	-	≤ 2 A (500 VA)	OK
		-	≤ 4 A (1000 VA)	
			≤ 7 A (2000 VA)	
	d. AC Output Voltage *)	114,9	190 – 230 VAC	OK
	e. Equipment Temperature	25,2	0-35 °C	OK

Notes / additional informations :

Inverter kondisi normal

Executor				Verifikator (_____))	Head Of Sub Departement (_____)
No	Nama	Mitra / Internal	Signature		
1	Adi	IMS			
2					
3					
4					