

No. Dok. : FM-LAP- D2-SOP-003-006	Formulir Preventive Maintenance Shelter Room / ODC	
Versi : 1.0		
Hal : 1 dari 1		
Label : Internal		

Location : Grand Mall Bekasi
 Date / time : Sabtu, 31 Januari 2025
 Type : Shelter

No.	Descriptions	Result	Operational Standard	Status (OK/NOK)
1.	Physical Check			
	a. Room Condition	Bersih	Clean, free from leaks, and free from contamination	OK
	b. Room / Shelter Lock Condition	Kuat	Durable and easily operable	OK
2.	Room Infrastructure			OK
	a. Room Layout	Normal	Functionality, maintainability, user comfort, and aesthetic	OK
	b. Security Management Control	Aman	Secure, *CCTV-monitored (optional)	OK
	c. Ease Of Access	Normal	Safe and efficient personnel movement, and ease of access to equipment	OK
	d. Technical Aspects	Tersedia	Availability of power supply, lightning protection, grounding system, lighting, air conditioning, fire protection, and *CCTVmonitored (optional)	OK
3.	Room Temprature		<25°C Shelter Room	OK
			<35°C Outdoor Cabinet (ODC)	OK
			<40°C Pole Outdoor Cabinet (ODC)	OK

Notes / additional informations :

<u>Shelter kondisi normal</u>

Executor				Verifikator	Head Of Sub Departement
No	Nama	Mitra / Internal	Signature		
1	Tazki	IMS		(_____) (_____)	
2					
3					
4					