

No. Dok. : FM-LAP- D2-SOP-003-007	Formulir Preventive Maintenance Rectifier	
Versi : 1.0		
Hal : 1 dari 1		
Label : Internal		

Location : Grand Mall Bekasi
 Date / time : Sabut, 31 Januari 2025
 Brand / Type : Eaton
 Kap.Power Module : Three *)

Reg. Number :BW7676767567
 S/N : 565454354

No.	Descriptions	Result	Operational Standard	Status (OK/NOK)
1.	Physical Check			
	a. Environment Condition	Clean	Clean, No dust	OK
	b. LED / display	Normal	Normal	OK
	c. Battery Connection	Tighten	Tighten, No Corrosion	OK
	d. Rectifier Module Installed			
	e. Alarm Modul Rectifier	Normal	Normal = Green Alarm = Red	OK
2	Performance and Capacity Check			
	a. AC Input Voltage	232,2	180-240 VAC	OK
	b. AC Current Input	-	≤ 5.5 A (Single Power Module) ≤ 11 A (Dual Power Module) ≤ 16.5 A (Three Power Module)	-
	c. DC Current Output	15	≤ 25 A (Single Power Module) ≤ 50 A (Dual Power Module) ≤ 75 A (Three Power Module)	OK
	d. Charging Voltage DC	53,40	48 – 55,3 VDC	OK
	e. Charging Current DC	0,17	Max 10% Battery Capacity (AH)	OK
	Backup Tests			
3	Rectifier Switching test, from the main source (PLN) to back up mode, by turning off Rectifier input MCB	-	Rectifier Normal Operations	-
4	Power Alarm Monitoring Test	-		-
	Makesure the alarm monitor, by turn off UPS power input MCB during Rect backup test operation	-	Alarm Monitor fault conditions (Red Sign / Alert "Alarm Input Voltage)	-

Notes / additional informations:

--

Executor				Verifikator	Head Of Sub Departement
No	Nama	Mitra / Internal	Signature		
1	Tazki	IMS		(_____) (_____)	
2					
3					
4					