

No. Dok. : FM-LAP- D2-SOP-003-010	Formulir Preventive Maintenance Battery	
Versi : 1.0		
Hal : 1 dari 2		
Label : Internal		

Location : Grand Mall Bekasi
 Date / time : 31 Januari 2025
 Battery Temperature : 24,4
 Battery Bank : 6

Bank : 1 UPS						Bank : 1 Recti					
Battery Type : Baterai Kering UPS						Battery Type : Baterai Kering Recti					
Battery Brand : Ritar						Battery Brand : Ritar					
End Device Batt : 65 AH						End Device Batt : 65 AH					
No	Voltage	SOH	No	Voltage	SOH	No	Voltage	SOH	No	Voltage	SOH
1	12,5	80	11	12,5	80	1	13,1	100	11		
2	12,6	58	12	12,7	100	2	13,5	100	12		
3	12,5	78	13	12,5	78	3	12,6	70	13		
4	12,4	88	14	12,4	88	4	13,5	100	14		
5	12,3	45	15	12,3	45	5			15		
6	12,6	80	16	12,6	80	6			16		
7	12,5	90	17	12,5	90	7			17		
8	12,4	80	18	12,4	80	8			18		
9	12,1	70	19	12,1	70	9			19		
10	12,2	70	20	12,2	70	10			20		

Bank : 2 UPS						Bank : 2 Recti					
Battery Type : Baterai Kering UPS						Battery Type : Baterai Kering Recti					
Battery Brand : Ritar						Battery Brand : Ritar					
End Device Batt : 80 AH						End Device Batt : 80 AH					
No	Voltage	SOH	No	Voltage	SOH	No	Voltage	SOH	No	Voltage	SOH
1	12,5	80	11	12,5	80	1	13,1	100	11		
2	12,6	58	12	12,7	100	2	13,5	100	12		
3	12,5	78	13	12,5	78	3	12,6	70	13		
4	12,4	88	14	12,4	88	4	13,5	100	14		
5	12,3	45	15	12,3	45	5			15		
6	12,6	80	16	12,6	80	6			16		
7	12,5	90	17	12,5	90	7			17		
8	12,4	80	18	12,4	80	8			18		
9	12,1	70	19	12,1	70	9			19		
10	12,2	70	20	12,2	70	10			20		

* Measurement with load test (backup test UPS /Rectifier)
 * Standard min 12 VDC/Battery
 * Standard SOH 80%

No. Dok. : FM-LAP- D2-SOP-003-010	Formulir Preventive Maintenance Battery	
Versi : 1.0		
Hal : 2 dari 2		
Label : Internal		

No.	Descriptions	Result	Operational Standard	Status (OK/NOK)
1.	Rectifier Switching test, from the main source (PLN) to back up mode, by turning off Rectifier input MCB	Normal		OK
	a. Battery voltage (on Backup Mode).	Normal		OK
	b. Measurement I (at the beginning)	50	Min 49 VDC	OK
	c. Measurement II (15 th minutes)	52,5	Min 48 VDC	OK

Notes / additional informations :

<u>Baterai Normal</u> <u>Tanggal Produksi battery 1 = 10/09/2021</u> <u>Tanggal Produksi battery 2 = 10/08/2021</u> <u>Baterai 2 berumur 5 tahun</u>
--

Executor				Verifikator	Head Of Sub Departement
No	Nama	Mitra / Internal	Signature		
1	ADI	IMS			
2					
3					
4					
				(_____)	(_____)