

SHRIRAM INSTITUTE FOR INDUSTRIAL RESEARCH

(A unit of Shriram Scientific and Industrial Research Foundation)

19, University Road, Delhi – 110007 (India) An ISO - 9001, 14001 & OHSAS 18001 Certified Institute Website: www.shriraminstitute.org
E-mail id: customercare@shriraminstitute.org

TEST CERTIFICATE

NO.: C1/0000101834

1710-1-141-753

RG1718/1/6564

Protocol Adopted

ASTM D 4060 - 14

09/10/2017

09/10/2017

Date 16/10/2017

Job No.

Booking No.

Booking Date

Customer Ref No.

Customer Ref Date

Issued To:

Client Code: A0631

ALSTONE INDUSTRIES PVT LTD

ALSTONE HOUSE, 2 E/7, JHANDEWALAN

EXTENSION

NEW DELHI

DELHI-110055

Kind Attn: MS. RAKSHANDA JABEEN

Sample Description:

ONE SAMPLE DESCRIBED AS ALSTONE FLOORXTRA- WPC FLOORING, WAS RECEIVED.

The sampling was not carried out by Shriam Institute for Industrial Research. The sample details provided in the test certificate are based on the decalaration by the party.

S.No Tests Results

1. Abrasion Test
i) Wear Index (I) 0.002
ii) Weight loss(L), g 0.016
(Wheels CS-17, Cycles-10000)

DOR: 09-10-2017 DOC: 16-10-2017

AUTHORISED SIGNATORY

AUTHORISED SIGNATORY EMPLOYEE CODE: (4159)

GC-01(Rev-05)

Page 1 of 1

Scanned copies/photocopies or any other copies should be authenticated by reference to the original report.

Phone: 91-11-27667267, 27667983, 27667860

Fax: 91-11-27667676, 27667207

See overleaf for terms & conditions

SR1-C1 (Rev. 02)