## Tubrial-6, 19114018, Ayushman Toupathy

Da By finst law, Q = DU+W

6

ib n=1 {100% efficiency}

 $\exists \eta = \underline{w} = 1 \Rightarrow \underline{w} = 0 \Rightarrow |\underline{\Delta}\underline{v} = 0|$ 

- this is possible acc. to first law - Doesn't violate of

6) The second law of thermodynamics is directly violated is n=1

As, conversion of all the heat into energy is
not possible. -> Kelvin - Planck Statement

{ It contradicts }

Violates 2nd Law

No, the efficiencies of all work producing devices don't necessarily violate K-P statement.

The K-P statement is applicable to clevice that produce work by transfer of heat blu heat source { reservoiry }

As, hydroelectric power plant and doesn't exchange heat with thermal resorvoirs 4 produce work from mechanical energy, they and all similar devices are not limited by Kelvin-Planck Stament

1000		11
0	Date	=0
R		

(B) OH = 6 KW , OL = 4KW , W = 2KW

QH = QK + W =) Satisfier finst law

n = 2 = 1 <1 : 2nd law outsfield

(b) Q; = 6 KW, QL = 0 KW, W = 6 KW

on = ont wi = borret law subisfied

 $\eta = \omega = 6 = 1 = 1$  and low violated

(d) Où = 6 kw , Où = 5 ko

On = 6 kw \$ On two = 7kw = 1st law violated

 $\eta = \underline{w} - \underline{5}$  < 1 = 2nd low satisfied = 0,  $\neq 0$ 

@ OH = 6KW, OH = 6KW, W=0 ROL

On - on + w =) 1st law satisfied

7(1 =) OL # O ~ satisfies and Law.

w = 500 kW 3 Griven ben refrigeration

cop = Heat extracted = OL =) 2.5 = OL conk done on sp w 500

= OL = 1250KW

OH = OL+W = 1250 + 900 = 1750KW

=1 net - effect on kitchen cur = 1750 kW

First law would be satisfied as it would state here, work done is by vitatue of cooling of air from 20'c to -20'c { was of heat by air account for work},

Second low would also be satisfied.

This statement concerns KP statement as it is of a heat engine. and here heat is being rejected to a low temporature resorvoin, thus, 2nd low is satisfied.

ie heat is being converted to work, with some heat being lost to low temp reservois by doesn't violate any 2nd low statements

 $\frac{do}{dt} = 60 \text{ tons } / h = 60 \times 10^3 \text{ kg/h}$ 


$$\frac{d0}{dt} = \frac{dm}{dt} \times \frac{heating}{value} = \frac{60 \times 10^3 \times g0000}{n} \times \frac{uJ}{n} = \frac{18 \times 10^9 \, RJ}{h}$$

 $\frac{100 - 1.8 \times 10^{9} \text{KJ/h} = 1.8 \times 10^{9} \text{ KJ/s}}{60 \times 60}$   $= 1 \times 10^{7} \text{ kw} = 5 \times 10^{5} \text{kw} = 500 \text{ Mw}$ 

 $\frac{1}{20} \times 10 \text{ kW} = 3 \times 1$ 

Given  $\bar{w} = 150 \text{MW}$ 

Then 
$$w = 150 \text{MW}$$
 $\eta = \frac{150}{2} = 0.3 = 1 \times \text{efficiency} = 30 \times 100 =$ 



 $\frac{6}{M} = 15090 \text{ KJ/h}$   $\frac{0}{M} = 10000 \text{ KJ/h}$   $\frac{1}{M} = 1.5 \text{ KW} = 1.5 \times 3600 \text{ KJ/h} = 5400 \text{ KJ/h}$ 

=> (OPHP =

A heat pump gives heat to a high temp. reservoirs after work is done on it by extracting heat from low T' xesorvoirs 4 maintains it at high T.

 $\frac{Q_{H}}{\dot{W}} = \frac{15090}{5400} = \frac{1}{2.7944}$ 

\_\_\_

\_\_\_

\_\_\_

2

Page \_\_\_\_

 $cop = ol = 2.5 = 0.5 = 0.00 = 450 \times 2.5 W = 1125 W$ 

Total heate required to be = n(mssT)
extracted

= 5 × 10 × 4-2 × (20-8) KJ

(0 rotal = 2520 KJ

 $\Rightarrow 0i \cdot t = 0 \text{ total} \Rightarrow t = 0 \text{ total} = 2520 \times 10^{3} \text{ s}$   $0i \cdot t = 2240 \text{ s}$ 

Q(0st = 60 000 NJ/N

For a neat pump,  $cop = OH = OH = \dot{O}H = \dot{O$ 

Energy consus st low for house 37 On + Ogen = Qust

 $\Rightarrow$  2.5  $\bar{W}$  + 4000 = 60000

=)  $\dot{W}$  =  $56000 \, \text{kJ/n} = 22400 \, \text{kJ/n} = 22400 \, \text{k}$  $2.5 \, 60 \times 60$ 

W = 6.222 KW

.: required Power input to heat pump = 6.222 NW

(10) Taking R-134-a au refrigerant @ 800 KPa ) 35 C - SOUMPa ab, 7 = 34'c 4 T=36'c w= 1-2 mw we have p = 863.11 kpd 0.018 kg/s and But = 912.35°C = P= 800 upg < Post

{\$P=863.11 + 912-35} => Superheated refrigerant initially COOPEOU PROMPO COPED FO DESCRIPTION At O. 8 MPa for supervisated R-1344, At T= 30'c , =1 h= 267-34 KJ/kg At T=400, n= 276.48 KJ/Kg By interpolation, At T=35C, n= hauthun  $n_1 = 271-9 \, \text{kJ/ks}$ Finally saturated liquid at 0.8 MPa =)  $h_{z} = h_{sat}$ , at 0-8MPa =  $h_{R} = 95.48 \text{ k} 3/\text{kg}$   $\frac{1}{N_{z}} = 95.48 \text{ k} 3/\text{kg}$ ση = m Δη = 0.018(271.9-95.43) = 3.17656 KJ/s = 3.1755 KW  $\frac{cop = 0\dot{n}}{np} = \frac{3.1755}{\dot{N}} = \frac{2.6463}{1.2} = \frac{2.6463}{1.2}$ (b) Rate of heat absomption = Oy-w= [1.9755 nw]

Page \_\_\_\_

(1) COPrefrigeration = 
$$\frac{Q_L}{W}$$
 =>  $\frac{Q_L}{450}$  = 1.2 =1  $\frac{Q_L}{W}$  = 540 % W

·: heat extracted = 540 mm

$$h_1 = (n_f + x h_{fg})$$
 at 120 KPa = 22.47 + 0.2 × 214-52

= 65.374 KJ/kg

$$= 1 \quad 20 = h - 239.52$$

$$= 242.90 - 239.52$$

$$|\hat{n} = 3.08587 \text{ kg/s} | \times 10^{-3} |$$

$$|\hat{n} = 0.0030857 \text{ kg/s} | \times 10^{-3} |$$

$$h = W = 4kW - 0.65$$

$$n = w = 4ekw = 0.65$$

Ogiven

Ogiven

=) Ogiven = 
$$6.1538 \times W$$
  
=  $6.1538 \times 3600 \times 5/h$   
Ogiven =  $22153.846 \times 5/h$ 

(3) TH = 160'C = 433K

TL = 25°C = 25+278 = 298 K

W = 22MW

On = mon

n, = 14 cet 160°C = 675.47 KIlng

hz = ht at 25° C = 108-77 KJ/kg SBorgnakne)

Qu= no Oh= 440x (675.47-108.77)

= 440 x 566.7 KW

= 249348 KW = 24.9348MW

(a)  $\eta = \hat{w} = 22 = 0.08823 = 8.8237$ .

6 nman = 1 - The S= noversible


2 1 - 298 = 0.311778


= 31.17784. & 31-2x.

0 Ou= On- ~ = 249398-22000 KW

= 227348 NW

COPMOX = OH = OH-OL House Up & 6KW
Tower. = TH Tswa TH-TL = 211273 Given, don= 5400 kJ/n°c 21 - T ¿ as equilibrium of house? = 294 294 ~ TL =1 On = 1-5 KW x (294 TL) COPMON = 194 = 294 TL = 1.5(294-TL) = 29424-TL = 1294 x4 = TL = 294-34-29 = 259-707K = T= (259-707-273)'C = -13.2928°C





В ос, не = Он, не - W = 800 - 595.396 = 204.604.ks/min

> Он, пер = W+ Оглер = (595-396+ 4986.445) ид Imis = 5581.841 ид Imis

-: O to ambient ain = O4, ref + O2, HE = 5786.445 kJ/min

= 1 - 0.25675

Total note of heat rejection to air | arei = 5786-44 KJ/min