

FreshFlow Beverages Pvt. Ltd.

FreshFlow Bottling Plant - Pune Production Facility
FSSAI: 10012022000345 | ISO 22000:2018 / ISO 14001:2015

INCIDENT REPORT

Incident Report: Environmental (Spill/Release)

Caustic spill

Equipment ID: BL103

Document Number: INC-060
Revision: Final
Classification: CONFIDENTIAL - INTERNAL USE ONLY
Prepared by: Engineering / QA Department
Approved by: Plant Manager

1. Incident Overview

1.1 Basic Information

Parameter	Value
Incident ID	INC-060
Type	Environmental (Spill/Release)
Date & Time	2023-02-28 16:40
Location / Department	Utilities
Associated Asset	BL103
Asset Name	BL103 Boiler
Reported By	Employee 9 (Operator)
Investigator	Anita Desai (QC Manager)

2. Description of Event

On 2023-02-28 at 16:40, an incident classified as 'Environmental (Spill/Release)' occurred. The primary observation was: 50L of 2% NaOH leaked from CIP return tank.. The area was secured by the shift supervisor immediately after the event.

The incident occurred during operation/maintenance of equipment BL103 (BL103 Boiler). Refer to equipment manual MAN-BL103-001 for technical context.

3. Immediate Actions Taken

- Secured the area and stopped relevant machinery (if applicable).
- Administered first aid / contained spill / quarantined product (as per incident type).
- Notified the Plant Manager and EHS/QC department.
- Initial mitigation applied: Neutralized with acid and washed to effluent. Replace tank level sensor.

4. Root Cause Analysis (Summary)

A formal investigation was conducted. The preliminary root causes identified include inadequate risk perception, equipment failure, or procedural deviation. (A full RCA report is generated separately for critical incidents).

5. Corrective and Preventive Actions (CAPA)

Action Description	Owner	Target Date	Status
Neutralized with acid and washed to effluent. Replace t	Anita Desai	2023-03-07	Closed
Review and update relevant SOP/RA	Employee 9	2023-03-14	In Progress
Conduct toolbox talk with shift team	Shift Supervisor	2023-03-02	Closed

6. Signatures & Closure

Report Prepared By: Employee 9
Date: 2023-03-01

Approved By: Anita Desai
Date: 2023-03-02