

FreshFlow Beverages Pvt. Ltd.

FreshFlow Bottling Plant - Pune Production Facility
FSSAI: 10012022000345 | ISO 22000:2018 / ISO 14001:2015

RCA REPORT

Root Cause Analysis (RCA)

Subject: Unexpected failure of UPS103 Power Backup causing production delay.

Equipment ID: UPS103

Document Number: RCA-068
Revision: Final
Classification: CONFIDENTIAL - INTERNAL USE ONLY
Prepared by: Engineering / QA Department
Approved by: Plant Manager

1. RCA Information

1.1 Overview

Parameter	Value
RCA ID	RCA-068
Date of RCA	2023-08-01
Reference Event/Incident ID	INC-169
Equipment / Asset	UPS103 - UPS103 Power Backup
Department	Utilities
Facilitator	Employee 20 (Engineer)
Methodology Used	Fishbone (Ishikawa)

2. Problem Statement

The following issue occurred leading to a disruption in operations, quality, or safety: Unexpected failure of UPS103 Power Backup causing production delay.. The immediate impact required corrective action to stabilize the process.

3. 5-Whys Analysis

The cross-functional team conducted a 5-Whys analysis to drill down to the systemic root cause.

Question	Answer
Why did the problem happen?	Unexpected failure of UPS103 Power Backup causing produ
Why?	Because of component/process failure.
Why did it fail?	Because it reached its operational limit / was out of s
Why was it out of spec?	Because: Wear and tear combined with missed preventive
Why? (Root Cause)	Systemic gap in maintenance plan or operational procedu

4. Identified Root Cause

Wear and tear combined with missed preventive maintenance schedule.
This has been classified as a systemic failure requiring permanent corrective action.

5. Corrective and Preventive Actions (CAPA)

Action Items	Owner	Target Date
Replace worn parts. Implement automated PM alerts in CM	Employee 20	2023-08-08
Update Equipment Manual and PM Schedule	Employee 19	2023-08-15
Train operators on new procedure	Employee 5	2023-08-22

6. Sign-off

Plant Manager Approval: _____

Date: 2023-08-03