

FreshFlow Beverages Pvt. Ltd.

FreshFlow Bottling Plant - Pune Production Facility
FSSAI: 10012022000345 | ISO 22000:2018 / ISO 14001:2015

INCIDENT REPORT

Incident Report: Safety (Near Miss)

LOTO violation observed

Equipment ID: BW103

Document Number: INC-100
Revision: Final
Classification: CONFIDENTIAL - INTERNAL USE ONLY
Prepared by: Engineering / QA Department
Approved by: Plant Manager

1. Incident Overview

1.1 Basic Information

Parameter	Value
Incident ID	INC-100
Type	Safety (Near Miss)
Date & Time	2023-03-24 18:58
Location / Department	Bottle Washing
Associated Asset	BW103
Asset Name	BW103 Bottle Washing Machine
Reported By	Employee 16 (Engineer)
Investigator	Rajesh Kulkarni (Plant Manager)

2. Description of Event

On 2023-03-24 at 18:58, an incident classified as 'Safety (Near Miss)' occurred. The primary observation was: Operator attempted to clear jam without isolation.. The area was secured by the shift supervisor immediately after the event.

The incident occurred during operation/maintenance of equipment BW103 (BW103 Bottle Washing Machine). Refer to equipment manual MAN-BW103-001 for technical context.

3. Immediate Actions Taken

- Secured the area and stopped relevant machinery (if applicable).
- Administered first aid / contained spill / quarantined product (as per incident type).
- Notified the Plant Manager and EHS/QC department.
- Initial mitigation applied: Retrain operator; issue formal warning.

4. Root Cause Analysis (Summary)

A formal investigation was conducted. The preliminary root causes identified include inadequate risk perception, equipment failure, or procedural deviation. (A full RCA report is generated separately for critical incidents).

5. Corrective and Preventive Actions (CAPA)

Action Description	Owner	Target Date	Status
Retrain operator; issue formal warning.	Rajesh Kulkarni	2023-03-31	Closed
Review and update relevant SOP/RA	Employee 16	2023-04-07	In Progress
Conduct toolbox talk with shift team	Shift Supervisor	2023-03-26	Closed

6. Signatures & Closure

Report Prepared By: Employee 16
Date: 2023-03-25

Approved By: Rajesh Kulkarni
Date: 2023-03-26