

FreshFlow Beverages Pvt. Ltd.

FreshFlow Bottling Plant - Pune Production Facility
FSSAI: 10012022000345 | ISO 22000:2018 / ISO 14001:2015

INCIDENT REPORT

Incident Report: Equipment (Major Breakdown)

Pump cavitation in water transfer line

Equipment ID: CV101

Document Number: INC-021
Revision: Final
Classification: CONFIDENTIAL - INTERNAL USE ONLY
Prepared by: Engineering / QA Department
Approved by: Plant Manager

1. Incident Overview

1.1 Basic Information

Parameter	Value
Incident ID	INC-021
Type	Equipment (Major Breakdown)
Date & Time	2023-05-20 10:00
Location / Department	Packaging
Associated Asset	CV101
Asset Name	CV101 Conveyor Belt
Reported By	Employee 17 (Operator)
Investigator	Farah Shaikh (Food Safety Officer)

2. Description of Event

On 2023-05-20 at 10:00, an incident classified as 'Equipment (Major Breakdown)' occurred. The primary observation was: Water pressure unstable, rattling noise, low transfer flow. The area was secured by the shift supervisor immediately after the event.

The incident occurred during operation/maintenance of equipment CV101 (CV101 Conveyor Belt). Refer to equipment manual MAN-CV101-001 for technical context.

3. Immediate Actions Taken

- Secured the area and stopped relevant machinery (if applicable).
- Administered first aid / contained spill / quarantined product (as per incident type).
- Notified the Plant Manager and EHS/QC department.
- Initial mitigation applied: Flush water line, replace filter cartridge, verify suction valve fully open

4. Root Cause Analysis (Summary)

A formal investigation was conducted. The preliminary root causes identified include inadequate risk perception, equipment failure, or procedural deviation. (A full RCA report is generated separately for critical incidents).

5. Corrective and Preventive Actions (CAPA)

Action Description	Owner	Target Date	Status
Flush water line, replace filter cartridge, verify suct	Farah Shaikh	2023-05-27	Closed
Review and update relevant SOP/RA	Employee 17	2023-06-03	In Progress
Conduct toolbox talk with shift team	Shift Supervisor	2023-05-22	Closed

6. Signatures & Closure

Report Prepared By: Employee 17
Date: 2023-05-21

Approved By: Farah Shaikh
Date: 2023-05-22