

FreshFlow Beverages Pvt. Ltd.

FreshFlow Bottling Plant - Pune Production Facility
FSSAI: 10012022000345 | ISO 22000:2018 / ISO 14001:2015

INCIDENT REPORT

Incident Report: Safety (Near Miss)

Slip/trip hazard observed

Equipment ID: BL101

Document Number: INC-109
Revision: Final
Classification: CONFIDENTIAL - INTERNAL USE ONLY
Prepared by: Engineering / QA Department
Approved by: Plant Manager

1. Incident Overview

1.1 Basic Information

Parameter	Value
Incident ID	INC-109
Type	Safety (Near Miss)
Date & Time	2023-07-07 04:14
Location / Department	Utilities
Associated Asset	BL101
Asset Name	BL101 Boiler
Reported By	Anita Desai (QC Manager)
Investigator	Anita Desai (QC Manager)

2. Description of Event

On 2023-07-07 at 04:14, an incident classified as 'Safety (Near Miss)' occurred. The primary observation was: Water pooling on floor near filler.. The area was secured by the shift supervisor immediately after the event.

The incident occurred during operation/maintenance of equipment BL101 (BL101 Boiler). Refer to equipment manual MAN-BL101-001 for technical context.

3. Immediate Actions Taken

- Secured the area and stopped relevant machinery (if applicable).
- Administered first aid / contained spill / quarantined product (as per incident type).
- Notified the Plant Manager and EHS/QC department.
- Initial mitigation applied: Install additional floor drain; immediate clean-up.

4. Root Cause Analysis (Summary)

A formal investigation was conducted. The preliminary root causes identified include inadequate risk perception, equipment failure, or procedural deviation. (A full RCA report is generated separately for critical incidents).

5. Corrective and Preventive Actions (CAPA)

Action Description	Owner	Target Date	Status
Install additional floor drain; immediate clean-up.	Anita Desai	2023-07-14	Closed
Review and update relevant SOP/RA	Anita Desai	2023-07-21	In Progress
Conduct toolbox talk with shift team	Shift Supervisor	2023-07-09	Closed

6. Signatures & Closure

Report Prepared By: Anita Desai

Date: 2023-07-08

Approved By: Anita Desai

Date: 2023-07-09