

FreshFlow Beverages Pvt. Ltd.

FreshFlow Bottling Plant - Pune Production Facility
FSSAI: 10012022000345 | ISO 22000:2018 / ISO 14001:2015

INCIDENT REPORT

Incident Report: Equipment (Major Breakdown)

Drive shaft shear

Equipment ID: P101

Document Number: INC-143
Revision: Final
Classification: CONFIDENTIAL - INTERNAL USE ONLY
Prepared by: Engineering / QA Department
Approved by: Plant Manager

1. Incident Overview

1.1 Basic Information

Parameter	Value
Incident ID	INC-143
Type	Equipment (Major Breakdown)
Date & Time	2023-03-09 11:09
Location / Department	Water Treatment
Associated Asset	P101
Asset Name	P101 Water Transfer Pump
Reported By	Employee 8 (Engineer)
Investigator	Rajesh Kulkarni (Plant Manager)

2. Description of Event

On 2023-03-09 at 11:09, an incident classified as 'Equipment (Major Breakdown)' occurred. The primary observation was: Main drive shaft on conveyor sheared due to overload.. The area was secured by the shift supervisor immediately after the event.

The incident occurred during operation/maintenance of equipment P101 (P101 Water Transfer Pump). Refer to equipment manual MAN-P101-001 for technical context.

3. Immediate Actions Taken

- Secured the area and stopped relevant machinery (if applicable).
- Administered first aid / contained spill / quarantined product (as per incident type).
- Notified the Plant Manager and EHS/QC department.
- Initial mitigation applied: Replace shaft. Install torque limiter on drive.

4. Root Cause Analysis (Summary)

A formal investigation was conducted. The preliminary root causes identified include inadequate risk perception, equipment failure, or procedural deviation. (A full RCA report is generated separately for critical incidents).

5. Corrective and Preventive Actions (CAPA)

Action Description	Owner	Target Date	Status
Replace shaft. Install torque limiter on drive.	Rajesh Kulkarni	2023-03-16	Closed
Review and update relevant SOP/RA	Employee 8	2023-03-23	In Progress
Conduct toolbox talk with shift team	Shift Supervisor	2023-03-11	Closed

6. Signatures & Closure

Report Prepared By: Employee 8
Date: 2023-03-10

Approved By: Rajesh Kulkarni
Date: 2023-03-11