

FreshFlow Beverages Pvt. Ltd.

FreshFlow Bottling Plant - Pune Production Facility
FSSAI: 10012022000345 | ISO 22000:2018 / ISO 14001:2015

INCIDENT REPORT

Incident Report: Environmental (Spill/Release)

CO2 release

Equipment ID: BL101

Document Number: INC-195
Revision: Final
Classification: CONFIDENTIAL - INTERNAL USE ONLY
Prepared by: Engineering / QA Department
Approved by: Plant Manager

1. Incident Overview

1.1 Basic Information

Parameter	Value
Incident ID	INC-195
Type	Environmental (Spill/Release)
Date & Time	2023-04-19 06:04
Location / Department	Utilities
Associated Asset	BL101
Asset Name	BL101 Boiler
Reported By	Employee 9 (Operator)
Investigator	Farah Shaikh (Food Safety Officer)

2. Description of Event

On 2023-04-19 at 06:04, an incident classified as 'Environmental (Spill/Release)' occurred. The primary observation was: Safety valve lifted on CO2 tank.. The area was secured by the shift supervisor immediately after the event.

The incident occurred during operation/maintenance of equipment BL101 (BL101 Boiler). Refer to equipment manual MAN-BL101-001 for technical context.

3. Immediate Actions Taken

- Secured the area and stopped relevant machinery (if applicable).
- Administered first aid / contained spill / quarantined product (as per incident type).
- Notified the Plant Manager and EHS/QC department.
- Initial mitigation applied: Area evacuated. Adjust regulator and replace safety valve.

4. Root Cause Analysis (Summary)

A formal investigation was conducted. The preliminary root causes identified include inadequate risk perception, equipment failure, or procedural deviation. (A full RCA report is generated separately for critical incidents).

5. Corrective and Preventive Actions (CAPA)

Action Description	Owner	Target Date	Status
Area evacuated. Adjust regulator and replace safety val	Farah Shaikh	2023-04-26	Closed
Review and update relevant SOP/RA	Employee 9	2023-05-03	In Progress
Conduct toolbox talk with shift team	Shift Supervisor	2023-04-21	Closed

6. Signatures & Closure

Report Prepared By: Employee 9
Date: 2023-04-20

Approved By: Farah Shaikh
Date: 2023-04-21